

Discharge Monitoring Report - STA 5 - Submittal Date: July 2004

Monitoring Period: April 01, 2004 - April 30, 2004

Permit # FL0177954-001

Discharge Point Number: D001

[] <Check if no discharge for reporting period

<small>NAME/TITLE/PRINCIPAL EXECUTIVE OFFICER</small> Linda J. Lindstorm, P.G., Director, Environmental Resource Assessment Department	<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS</small>	<small>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</small>	TELEPHONE NO. 561-682-6820	DATE 7/7/2004			
Parameter	Storet No. & Monitoring Location Code	Sample Type	Sample Frequency	CONCENTRATIONS			
				MIN (Monthly)	Annual Average	MAX (Monthly)	Units
Flow	50050 1 EFF-1 outflow G344A	Calc	Daily		70	4	cfs
Dissolved Oxygen	00300 1 EFF-1 outflow G344A	In Situ	Weekly	3.68			mg/l
Dissolved Oxygen	00300 5 SWU-1 inflow G342A	In Situ	Weekly	6.15			mg/l
pH	00400 1 EFF-1 outflow G344A	In Situ	Weekly	7.43		7.91	SU field
Total Phosphorus	00665 Y EFF-1 outflow G344A	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.054		mg/l as P
Total Phosphorus	00665 P SWU-1 inflow G342A	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.176		mg/l as P

Discharge Monitoring Report - STA 5 - Submittal Date: July 2004

Monitoring Period: April 01, 2004 - April 30, 2004

Permit # FL0177954-001

Discharge Point Number: D002

[] <Check if no discharge for reporting period

<small>NAME/TITLE/PRINCIPAL EXECUTIVE OFFICER</small> Linda J. Lindstrom, P.G., Director, Environmental Resource Assessment Department	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS	<small>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</small>	TELEPHONE NO. 561-682-6820	DATE 7/7/2004			
Parameter	Storet No. & Monitoring Location Code	Sample Type	Sample Frequency	CONCENTRATIONS			
				MIN (Monthly)	Annual Average	MAX (Monthly)	Units
Flow	50050 1 EFF-2 outflow G344B	Calc	Daily		66	1	cfs
Dissolved Oxygen	00300 1 EFF-2 outflow G344B	In Situ	Weekly	4.65			mg/l
Dissolved Oxygen	00300 5 SWU-2 inflow G342B	In Situ	Weekly	6.33			mg/l
pH	00400 1 EFF-2 outflow G344B	In Situ	Weekly	7.59		8.54	SU field
Total Phosphorus	00665 Y EFF-2 outflow G344B	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.085		mg/l as P
Total Phosphorus	00665 P SWU-2 inflow G342B	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.169		mg/l as P

Discharge Monitoring Report - STA 5 - Submittal Date: July 2004

Monitoring Period: April 01, 2004 - April 30, 2004

Permit # FL0177954-001

Discharge Point Number: D003

[] <Check if no discharge for reporting period

<small>NAME/TITLE/PRINCIPAL EXECUTIVE OFFICER</small> Linda J. Lindstrom, P.G., Director, Environmental Resource Assessment Department	<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS</small>	<small>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</small>	TELEPHONE NO. 561-682-6820	DATE 7/7/2004			
Parameter	Storet No. & Monitoring Location Code	Sample Type	Sample Frequency	CONCENTRATIONS			
				MIN (Monthly)	Annual Average	MAX (Monthly)	Units
Flow	50050 1 EFF-3 outflow G344C	Calc	Daily		26	1	cfs
Dissolved Oxygen	00300 1 EFF-3 outflow G344C	In Situ	Weekly	2.51			mg/l
Dissolved Oxygen	00300 5 SWU-3 inflow G342C	In Situ	Weekly	5.69			mg/l
pH	00400 1 EFF-3 outflow G344C	In Situ	Weekly	7.57		8.42	SU field
Total Phosphorus	00665 Y EFF-3 outflow G344C	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.202		mg/l as P
Total Phosphorus	00665 P SWU-3 inflow G342C	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.270		mg/l as P

Discharge Monitoring Report - STA 5 - Submittal Date: July 2004

Monitoring Period: April 01, 2004 - April 30, 2004

Permit # FL0177954-001

Discharge Point Number: D004

[] <Check if no discharge for reporting period

<small>NAME/TITLE/PRINCIPAL EXECUTIVE OFFICER</small> Linda J. Lindstrom, P.G., Director, Environmental Resource Assessment Department	<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS</small>	<small>SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT</small>	TELEPHONE NO. 561-682-6820	DATE 7/7/2004			
Parameter	Storet No. & Monitoring Location Code	Sample Type	Sample Frequency	CONCENTRATIONS			
				MIN (Monthly)	Annual Average	MAX (Monthly)	Units
Flow	50050 1 EFF-4 outflow G344D	Calc	Daily		26	0	cfs
Dissolved Oxygen	00300 1 EFF-4 outflow G344D	In Situ	Weekly	3.61			mg/l
Dissolved Oxygen	00300 5 SWU-4 inflow G342D	In Situ	Weekly	3.83			mg/l
pH	00400 1 EFF-4 outflow G344D	In Situ	Weekly	7.65		8.49	SU field
Total Phosphorus	00665 Y EFF-4 outflow G344D	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.141		mg/l as P
Total Phosphorus	00665 P SWU-4 inflow G342D	Grab / Flow - Proportional Composite	Weekly		Flow -w t Mean 0.512		mg/l as P